




WATER ANALYSIS REPORT

Sample ID	DIB/DLL/2026-27/0383		Revenue Collected (Yes/No)	Yes
Issued to	Sampoorna Kendra Vidyalaya		Sample Received Date	12/5/2026
Pin point	Sampoorna Kendra Vidyalaya		Block	K.C Gogoi Path
GP	N/A		Village	Dibrugarh, Assam
Type of Source	Filter Water		Source Installed	Self
Sample Collected By	The Principal			
Quantity	1500ml		Sample Collected On	12/5/2026
Date of Analysis Started	12/5/2026		Date of Analysis Completed	13/5/2026

Sl. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence of better alternate source)	
1	Residual Chlorine	APHA 4500-Cl B	0	0.2	1	mg/L
MICROBIOLOGICAL TEST						
2	E. Coli	MF	Not Detected in 100 ml	0	No Relaxation	CFU
3	Total Coliform	MF	Not Detected in 100 ml	0	No Relaxation	CFU

Notes: NA: Not Available/Not Applicable, NT: Not Tested, BDL: Below Detection Limit

1. The Results given above are related to the samples received and tested in this laboratory. Reliable of samples lies with the sender.
2. The test report cannot be regenerated /re-produced in whole or in part without written permission of laboratory
3. The test report cannot be used for any publicity and legal purpose.
4. The test samples meant for chemical analysis will be disposed off after 7 days from the date of completion of analysis of the sample unless until specifically requested by the customer for retaining over a longer period.



Authorised Signatory

(Jyotshna Sonowal)
Quality Manager
DLL Dibrugarh (PHE)



WATER ANALYSIS REPORT

ULR NO.:	TC15474260	0000047	F	Date of Issue	
Sample ID	DIB/DLL/2026-27/0383		Revenue Collected (Yes/No)	Yes	
Issued to	Sampoorna Kendra Vidyalaya		Sample Received Date	12/05/2026	
Pin point	Sampoorna Kendra Vidyalaya		Block	K.C Gogoi Path	
GP	N/A		Village	Dibrugarh, Assam	
Type of Source	Filter Water		Source Installed	Self	
Sample Collected By	The Principal				
Quantity	1500ml		Sample Collected On	12/05/2026	
Date of Analysis Started	12/5/2026		Date of Analysis Completed	13/5/2026	

Sl. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence of better alternate source)	
PHYSICAL TEST						
1	pH	IS: 3025: Part 11	5.14	6.5 - 8.5	No relaxation	pH Units
2	TDS	IS: 3025: Part 16	24	500	2000	mg/L
3	Turbidity	IS: 3025: Part 10	0.3	1	5	NTU
4	Colour	IS: 3025: Part 4	5	5	15	CU
5	Odour	IS: 3025: Part 5	Agreeable	Agreeable	Agreeable	
6	Taste	IS: 3025: Part 8	Agreeable	Agreeable	Agreeable	
CHEMICAL TEST						
7	Chloride	IS: 3025: Part 32	22.69	250	1000	mg/L
8	Total Hardness	IS: 3025: Part 21	16	200	600	mg/L
9	Total Alkalinity	IS: 3025: Part 23	50	200	600	mg/L
10	Calcium	IS: 3025: Part 40	BDL	75	200	mg/L
11	Magnesium	APHA-3500- Mg B	2.91	30	100	mg/L
12	Iron	APHA-3500-Fe B	0.23	1	No Relaxation	mg/L
13	Nitrate	APHA 4500 NO3 B	1.84	45	No Relaxation	mg/L
14	Sulphate	APHA-4500- SO4 E	2.85	200	400	mg/L
15	Fluoride	APHA 4500 F D	BDL	1	1.5	mg/L
16	Arsenic	IS:3025: Part 37	BDL	0.01	No Relaxation	mg/L

Notes: NA: Not Available/Not Applicable, NT: Not Tested, BDL: Below Detection Limit

1. The Results given above are related to the samples received and tested in this laboratory. Reliability of samples lies with the sender.
2. The test report cannot be regenerated /re-produced in whole or in part without written permission of laboratory
3. The test report cannot be used for any publicity and legal purpose.
4. The test samples meant for chemical analysis will be disposed off after 7 days from the date of completion of analysis of the sample unless until specifically requested by the customer for retaining over a longer period.

Authorised Signatory

Jyotshna

(Jyotshna Sonowal)
Quality Manager
DLL Dibrugarh (PHE)

